

PT. PETROTEC AIR POWER

JOB REPORT NO. JRA44370

Customer : TATA METAL LESTARI			WO No : WOA22859			Date : 15-02-2025							
Address : Kawasan Industri Lippo Cikarang			Model : AS-5507			Serial no : CN0122060107							
Airend PN : 88250120-600			Airend SN : CN0122050399			Hourmeter : 6158							
Type Of Job :	PSU		SU		V		M	✓	TS				
INDICATION / SYMPTOM :													
Service 2000 jam													
PROBABLE CAUSES :													
1.					6.								
2.					7.								
3.					8.								
4.					9.								
5.					10.								
ACTIONS :													
- Ganti primary air filter - Ganti secondary air filter - Ganti oil filter - Top up drain - Tes running - Cek kebocoran - Cek parameter - Cek level oli													
REPLACEMENT PART													
QTY		VALUE				NAME			BATCH				
1		88290002-338				ELEMENT, SECOND AIR FILTER			1049138				
1		88290002-337				ELEMENT, PRIMARY AIR FILTER			1049137				
1		250025-526				ELEMENT, FLUID FILTER			1049139				
1		990130-082				GREASE PEERLESS LLG			1049140				
VOLT		PARAMETER SETTING				AMPERE			PRESSURE				
L1 - L2	408					L1	L2	L3	P1	P2	Δ P1	P3	P4
L2 - L3	408	LOAD	6.3			102	102	102	0	7	0	0	0
L1 - L3	408	UNLOAD	7			0	0	0	0	0	0	0	0
TEMPERATURE			ΔP			COOLER DATA							
T1	T2	Amb T	ΔP1	ΔP2	ΔP3	AIR TEMP		OIL TEMP		WATER TEMP		WATER IN Press	
88	0	35	0	0	0	IN	OUT	IN	OUT	IN	OUT		
						55	45	78	61	0	0	0	
RESULT & FURTHER RECOMMENDATIONS :													
Part part sudah diganti, dan Kompresor running dengan normal													
SPARE PARTS REQUIREMENT (IF ANY)													
"This report has been approved by customer through OTP basis and is automatically generated by Chronos-System of Petrotec Air Power, thus no Signature is required."													
Approved by : Bp. Johan							Technician(s) : Muhammad Ibnu Kamajaya						